

Pixley Irrigation District
ADDENDUM NUMBER 1 – PAGE 1
July 26, 2023

Lateral #4 – Construction Materials

ADDENDUM NUMBER 1 – (AD 2)

This addendum consists of one (1) page. The following additions shall become part of the RFP for this project:

ITEM NO. 1: What is the desired specification for the 36” pvc pipe and or what is the pressure that this line will be under?

-The Proposal shall reflect 100 PSI PIP PVC.

NOTE: Please keep a copy of this document for reference.



John Michael Domondon
District Engineer
Lower Tule River and Pixley Irrigation District

07/26/2023

Date